

TFI Report 452039-15

Thermal Resistance

Customer

LG Hausys Ltd.
One IFC, 20 Yeouido-gong, Yeongdeungpo-gu
150-876 Seoul
SOUTH KOREA

Product

resilient floor covering
Medistep Allroad

Responsible at TFI

Dr.-Ing. Heike Kempf
Tel: +49 241 9679 171
h.kempf@tfi-online.de

This report includes 2 pages and 1 annex(es)

This report is a transcription of test report no. 452039-01.

Aachen, 14.01.2016



Dr. Ernst Schröder

The present document is provided with a qualified electronic signature and is valid without autograph signature.

This report only applies to the tested specimens and has been established to the best of our knowledge. Only the entire report shall be reproduced. Under no circumstances, extracts shall be used. Furthermore, we apply the "General Terms and Conditions for the Execution of Contracts" of the Textiles & Flooring Institute GmbH, also with regard to the order execution.

1 Transaction

Test order	thermal resistance according to EN 12667
Order date	18.11.2015
Your reference	Dan Bi
Product designation	Medistep Allroad
TFI sample number	15-11-0188

2 Product Specification

Use surface	PVC*
Construction	homogeneous
Structure	flat
Pattern	tonal effect without pattern
Colour of the use surface	beige, light beige
View	



Thickness [mm]	2.0*
Area density [g/m²]	2950*
Type of delivery	broadloom
	*customer information

3 Results

Thermal resistance	$R = 0,0113 \text{ [m}^2\text{K/W]}$
--------------------	--------------------------------------

4 Annexes

Thermal resistance	WD 452039-15 ^a
--------------------	---------------------------

The annexes marked ^a are based on tests accredited in accordance with EN ISO/IEC 17025.

Annex WD - Thermal Resistance

1 Transaction

Product designation	Medistep Allroad
TFI sample number	15-11-0188
Testing period	18.12.2015 - 19.12.2015

2 Test Method / Requirements

Test method	EN 12667:2001 Determination of thermal resistance by means of guarded hot plate and heat flow meter methods - Dry and moist products with medium and low thermal resistance
Test device	One-specimen apparatus, horizontal
Conditioning	24 h storage according to EN ISO 139:2011 (23°C and 50% rel. humidity)
Thickness built-in [m]	0,0059
Number of Layer	3
Density [kg/m³]	1475

3 Results

Test	T_1 [°C]	T_2 [°C]	ΔT [K]	T_m [K]	R [m²·K/W]
1	17.3	27.4	10.1	22.4	0.03165
2	27.1	37.1	10.0	32.1	0.02949
3	37.0	46.9	9.9	41.9	0.02795
Calculated thermal resistance $1/\Lambda_{10}$ one layer at a mean temperature of 10 °C [m²k/W]					0.0113

T_1 : temperature of the cold surface of the specimen

T_2 : temperature of the warm surface of the specimen

ΔT : temperature difference; $\Delta T = T_1 - T_2$, T_m

T_m : average temperature of the specimen; $T_m = T_1 + T_2$

R : Increment of thermal resistance

Comments: none