

TFI Report 440893-13

Testing of Resilient Floor Coverings

Customer

LG Hausys Ltd.
One IFC, 20 Yeouido-gong, Yeongdeungpo-gu
150-876 Seoul
SOUTH KOREA

Product

Resilient floor covering
DECOCLICK

Responsible at TFI

B. Sc. Katharina Keulen
Tel: +49 241 9679 151
k.keulen@tfi-online.de

This report includes 2 pages and 1 annex(es)

Aachen, 4 09 2014



Dr. Ernst Schröder

The present document is provided with a qualified electronic signature and is valid without autograph signature.

This report only applies to the tested specimens and has been established to the best of our knowledge. Only the entire report shall be reproduced. Under no circumstances, extracts shall be used. Furthermore, we apply the "General Terms and Conditions for the Execution of Contracts" of the Textiles & Flooring Institute GmbH, also with regard to the order execution.

1 Transaction

Test order	Castor chair test according to EN 425:2002
Order date	13 June 2014
Your reference	Dan Bi
Product designation	DECOCLICK
TFI sample number	14-06-0095

2 Product Specification

Use surface	PVC*
Construction	heterogeneous
Structure	embossed*
Pattern	patterned
Colour of the use surface	brown, dark brown, black
Type of delivery	planks
	*customer information

3 Results

Castor chair	no damage
--------------	-----------

4 Annexes

Castor Chair	S 440893-13
--------------	-------------

The annexes marked ^a are based on tests accredited in accordance with EN ISO/IEC 17025.

Annex S- Castor Chair

1 Transaction

Product designation DECOCLICK
 TFI sample number 14-06-0095
 Testing period 2 July 2014 – 8 July 2014

2 Test Method / Requirements

EN 425:2002 Castor chair test
 Deviations None
 Adhesive Double-sided adhesive tape
 Number of cycles 25000

3 Results

Type of damage	Observation
Delamination	no
Opening of seam(s)	no
Cracks	no

Comments: none